

199—45.2 (476) Scope.

45.2(1) This chapter applies to utilities, and distributed generation facilities seeking to operate in parallel with utilities, provided the facilities are not subject to the interconnection requirements of the Federal Energy Regulatory Commission (FERC), the Midwest Independent Transmission System Operator, Inc. (MISO), or the Mid-Continent Area Power Pool (MAPP).

45.2(2) If the nameplate capacity of the facility is greater than 10 MVA, the interconnection customer and the utility shall start with the Level 4 review process and agreements under rules 199—45.11(476), 199—45.17(476), 199—45.18(476), 199—45.19(476), and 199—45.20(476), and modify the process and agreements as needed by mutual agreement. In addition, the interconnection customer and the utility shall start with the technical standards under rule 199—45.3(476) and modify the standards as needed by mutual agreement. If the interconnection customer and the utility cannot reach mutual agreement, the interconnection customer may seek resolution through the rule 199—45.12(476) dispute process.

[ARC 8859B, IAB 6/16/10, effective 7/21/10]